

District heating utilities of Veitur Utilities

Veitur's heating utilities with quantities of water produced, comments and improvements. In 2017, construction began on a new pumping station in Gardabær, which will serve the residents of Gardabær and Hafnarfjörður. The pumping station will be opened in the autumn of 2018. Some actions were undertaken in West and South Iceland to ensure the operability of district heating utilities..

Utility	Production field	Number of wells	Annual production thous. tons	l/s	Quantity	Comments	Improvements
Capital area							
	Laugarnes	10	5,184	164	Sufficient		
	Elliðaár	7	1,818	58	Sufficient		
	Reykir	22	12,963	411	Sufficient	Wholesale to Mosfellsbaer	
	Reykjahlid	12	15,693	498	Sufficient	Wholesale to Mosfellsbaer	
	Nesjavellir	18	27,472	871	Sufficient		
	Hellisheidi	31	9,877	313	Sufficient		
West Iceland							
	Deildartunga hot spring	1	4,031	128	Limited		Further research to provide hot water to continue in 2018
HAB	Wells in Baeir	2	435	14	Limited		
Skorradalur	Well in Stóra Drageyri	1	259	8	Sufficient		
Munadarnes	Well in Munadarnes	1	220	7	Sufficient		
Nordurardalur utility	Well in Svartagil	3	420	13	Sufficient		
	Well at Bifröst	1	115	4	Sufficient		
Stykkisholmur	Wells in Stykkisholmur	2	815	26	Sufficient	One injection well and back-up power	
South Iceland							
Hveragerdi	Borholur í Hveragerdi	2	1,054	33	Limited	Steam utility and closed circuit systems	Work on improvements regarding the reservoir
Ölfus	Bakki II	1	120	4	Sufficient		
Thorlakshofn	Bakki I	2	1,183	38	Sufficient		
Austurveita utility	Wells in Gljufurarholt	3	474	15	Sufficient	Part of the water used in Hveragerdi	
Grímsnes utility	Wells in Öndverðarnes	3	1,855	59	More than ample	Two wells in use	
Hlíðarveita utility	Wells at Efri-Reykir	1	688	22	Sufficient	The well provides water for two utilities	
Rangá utility	Wells at Kaldarholt	2	2,124	67	Sufficient		Work on production capacity and prepare research to provide hot water
	Wells in Laugaland	2	382	12	Limited		