

Sea water quality by Reykjavík

The percentage (%) of samples below limits, i.e., less than 100 in a 100 ml sample at the coast by Reykjavik and less than 1000 in a 100 ml sample at the periphery of dilution areas for the period 2013-2017.

Samples	Heat-tolerant microbes		2013	2014	2015	2016	2017
At the coast							
RDEP and Veitur Utilities	Faecal coliforms	%	90	86*	92*	85*	81*
	Enterococci	%	99	95*	96*	95*	96*
At the periphery of dilution areas							
Veitur Utilities	Faecal coliforms	%		97	97	100	100
	Enterococci	%		100	100	100	100

* Since 2014, Veitur Utilities have collected samples in addition to those collected by Reykjavik's Department of Environment and Planning (RDEP), and the findings are shown in the table.