

## Water level in Lake Skorradalsvatn 2017

In 2017 the goal of keeping the flow below the Andakílsá Hydropower Station within limits to ensure it is no less than 2 m<sup>3</sup>/s was achieved to safeguard the river's ecosystem and salmon, despite the environmental incident in the spring of 2017.

Apart from a few days between January and March, water level fluctuation targets in Lake Skorradalsvatn were met and within the limits, which are 1.08 m in normal operations in the winter and 0.4 m in the summer.

